

J.C. Broderick & Associates, Inc.

Environmental/Construction Consulting & Testing

June 20, 2016

Mr. Angelo Lisa
Bethpage Union Free School District
Administration Building
10 Cherry Avenue
Bethpage, New York 11714

**Re: Summary of Lead in Water Sampling
Bethpage Union Free School District**

Sites: Administration Building Bethpage High School
JFK Middle School Charles Campagne Elementary School
Kramer Lane School Central Boulevard Elementary School

JCB#: 16-34337

Dear Mr. Lisa:

J. C. Broderick & Associates, Inc. (JCB) was retained by the Bethpage Union Free School District to perform an assessment and testing of the drinking water outlets servicing the above referenced school buildings for the presence of lead.

The assessment and testing was performed in accordance with the United States Environmental Protection Agency (EPA's) protocols as recommended in their publication 3Ts for Reducing Lead in Drinking Water in Schools. The testing was performed at each drinking water outlet identified by the plumbing profile.

Locations which reported concentrations above the EPA action level were immediately taken out of service by the district. Additionally, certain water coolers were removed from service until their manufacturing data can be verified.

In summary, the results of the assessment, testing, and retesting concluded the following:

- Results from only nine (9) of one hundred ninety-three (193) locations exceeded the EPA action level. These locations have since been removed from service. Therefore, no elevated concentrations of lead were reported for any of the currently active drinking water outlets in the Bethpage Union Free School District

Please reference the full report for details pertaining to the assessment and testing methodology as well as the sample locations and laboratory analytical reports.

If you have any questions, or if more information is needed, please contact our office.

Sincerely,



Edward McGuire
J.C. Broderick & Associates, Inc.

