

Results of Water Quality Testing in Bethpage School District

Summary of report from J.C. Broderick & Associates

Charles Campagne Elementary School	<ul style="list-style-type: none">-Tested 20 fountains and faucets-All were below thresholds established by EPA for lead
Kramer Lane Elementary School	<ul style="list-style-type: none">-Tested 29 fountains and faucets-All were below thresholds established by EPA for lead
Central Blvd. Elementary School	<ul style="list-style-type: none">-Tested 43 fountains and faucets-38 were below thresholds established by EPA for lead-5 were above the recommended threshold on the first test of the day, but were below on subsequent tests that followed-All 5 were immediately turned off-New plumbing fixtures were ordered and installed and we await new tests on those classrooms-Additionally, we are replacing any fixture that was of the same model as those we were required to replace (even if EPA thresholds were acceptable)
JFK Middle School	<ul style="list-style-type: none">-Tested 58 fountains and faucets-57 were below thresholds established by EPA for lead-1 sink in a classroom was above the recommended threshold on the first test of the day, but was below on subsequent tests that followed-The one faucet was immediately turned off-New plumbing fixture was ordered and installed and we await new tests on that classroom
Bethpage High School	<ul style="list-style-type: none">-Tested 39 fountains and faucets-37 were below thresholds established by EPA for lead-2 were above the recommended threshold on the first test of the day, but were below on subsequent tests that followed-Both faucets were immediately turned off-New plumbing fixtures were ordered and installed and we await new tests on those classrooms <p>*A separate water cooler in the Custodial Maintenance Shop also tested above the threshold and has been removed from service.</p>