

Results of Water Quality Testing in Bethpage School District

Summary of report from J.C. Broderick & Associates

Updated November 8, 2016

<p>Charles Campagne Elementary School</p>	<p>-Tested 20 fountains and faucets -All were below thresholds established by EPA for lead</p>
<p>Kramer Lane Elementary School</p>	<p>-Tested 29 fountains and faucets -All were below thresholds established by EPA for lead</p>
<p>Central Blvd. Elementary School</p>	<p>-Tested 43 fountains and faucets -38 were below thresholds established by EPA for lead -5 were above the recommended threshold on the first test of the day, but were below on subsequent tests that followed -All 5 were immediately turned off -New plumbing fixtures were ordered and installed and we await new tests on those classrooms -Additionally, we are replacing any fixture that was of the same model as those we were required to replace (even if EPA thresholds were acceptable) -November- Only one faucet is still above the threshold (Room 205)- It remains out of service</p>
<p>JFK Middle School</p>	<p>-Tested 58 fountains and faucets -57 were below thresholds established by EPA for lead -1 sink in a classroom was above the recommended threshold on the first test of the day, but was below on subsequent tests that followed -The one faucet was immediately turned off -New plumbing fixture was ordered and installed and we await new tests on that classroom -November- Only one faucet is still above the threshold (Cafeteria)- It remains out of service</p>
<p>Bethpage High School</p>	<p>-Tested 39 fountains and faucets -37 were below thresholds established by EPA for lead -2 were above the recommended threshold on the first test of the day, but were below on subsequent tests that followed -Both faucets were immediately turned off -New plumbing fixtures were ordered and installed and we await new tests on those classrooms</p> <p>*A separate water cooler in the Custodial Maintenance Shop also tested above the threshold and has been removed from service.</p>